



NOTES
 - All supply branches to be 6 feet minimum.
 Try to maintain approximately 10 feet length.
 Each branch to have 3 feet minimum of
 sound attenuation tubing.

ENERLOSS
 INC.

HVAC Design
 R.R. 1 Hartington ON
 613.374.5284
 enerloss@sympatico.ca

- trunk duct
- branch duct
- supply
- return
- Unico supply tube
- ⊗ Unico diffuser
- ⊞ ceiling return

| | |
|---------------------------------------------------------|-------------------|
| project name SAMPLE | |
| drawing name High Velocity System | |
| installing contractor | |
| date (d/m/y) 00/00/00 | plot scale NTS |
| files CAD-wolsley1/sample-unico HCA - #301-sample | |